

**MAGILL SERVICES, INC.**

137 Elk Drive  
Murrells Inlet, SC 29576

Tel (843) 652-7000 Fax (843) 652-7002  
www.magillservicesinc.com

---

**LABORATORY REPORT**

**OLL 18030**

Date: March 8, 2016

Test Report # 160208

**THE COOLEY GROUP**

50 Esten Avenue  
Pawtucket, RI 02860

Subject: One (1) sample of fabric tested for flame resistance in accordance with  
**NFPA 701-2010, Test Method 2 (Flat Configuration).**

Identification: **Cooley Brite**

Testing Completed: March 8, 2016

---

**TEST, UNIT OF MEASURE**

**RESULTS**

**REQUIREMENTS**

**Flame Resistance**  
(NFPA 701-2010)

**Test Method 2 – Flat Configuration**

**After flame, seconds**

0.0  
0.0  
0.0  
1.6  
0.0  
0.0  
0.0  
0.0  
0.0  
1.1

Average:

0.3

2.0 Maximum

This report is for the exclusive use of the client to whom it is addressed and its communication to any others or use of the name Magill Services, Inc. must receive our prior written approval. This report is applicable only to the sample or samples tested.

**MAGILL SERVICES, INC.**

**TEST, UNIT OF MEASURE**

**RESULTS**

**REQUIREMENTS**

**Flame Resistance**  
(NFPA 701-2010)

**Test Method 2 – Flat Configuration**

**Char Length, inches**

8.1  
8.5  
8.2  
9.2  
8.2  
9.2  
8.6  
8.5  
9.3  
9.5

Average:

8.7

17.1 Maximum

**Drippings and flaming, seconds**

0.0  
0.0  
0.3  
0.3  
0.0  
0.0  
0.0  
0.0  
0.0  
0.0


Average:

0.1

2.0 Maximum

The sample tested above **meets** the requirements outlined in **Chapter 15 of NFPA 701-2010, Test Method 2.**

I certify that the above tests were performed under my supervision in accordance with the specification test requirements and that the reported test results are true, valid and applicable to the samples tested. I further certify that these samples are the only samples tested from the lot of components identified above.

Signed   
Edward L. Magill Jr.  
President